



**Главен паропровод
100 кг/см²
ЕК-9**

PEVNÝ BOD
 KLUZNÁ PODPĚRA
 POLOMĚR ZAKŘIVENÍ OHYBŮ R = 5 Js
 VÁHA 1bm ISOLACE + NAPLNĚNÍ POTRUBÍ Js 300
 Js 250
 POTRUBÍ Js 300
 POTRUBÍ Js 250
 MATERIÁL POTRUBÍ
 PROVOZNI TEPLOTA
 PROVOZNI TLAK

X	
Y	
1,250 m	
105 kp	
93 kp	
Ø 324 x 28 mm	Ø 324 x 36m
Ø 273 x 25 mm	Ø 273 x 32mm
15 t28.5	
540 °C	
9,7 MPa	

2-PZ 1

VIZ. PROJ. 1-04486/a	VIZ. PROJ. 2-03166/a	TEC SOFIA - V. ROZŠÍŘENÍ
10.5.1977	10.5.1977	220 t/h 25 MW
10.5.1977	10.5.1977	10.5.1977
PAROVOD I.		3-02728/a